



消防 無窓階算定
 $1.6 \times 1.8 \times 4 = 11.52$

$$11.52 > 153.5/30 = 5.11 \quad \therefore \text{有惡階}$$